REGINA | City of Regina
Infinite Horizons

2014 Drinking Water Quality Data

Water quality data presented below has been compiled from the results of laboratory testing. Water samples were taken from the Buffalo Pound Water Treatment Plant and comprehensive water quality analyses for all parameters were conducted in the plant laboratory.

Water quality test results for bacteriological, chlorine residual and turbidity were given in the 2014Dinking Water Quality and Compliance Report.

Parameter	Testing Result Annual Average	Saskatchewan Environment Water Quality Objective
Sodium (Na)	73	**<200 (AO)**
Sulphate (SO4)	223	**<500 (AO)**
Total Dissolved Solids (TDS)	**538**	**1500**
Manganese (Mn)	0	**0.05 (AO)**
Nitrate (NO3)	0	**45**
Potassium (K)	8	**No Standard**
Hardness	231	**800**
Iron (Fe)	0	**0.3 (IMAC)**
Magnesium (Mg)	26	**200**
Calcium (Ca)	**50**	**No Standard**
Chloride (Cl)	**28**	**<250 (AO)**
Fluoride (F)	**0**	**1.5**
Alkalinity (CaCO3)	**136**	**500**

Notes:

1. Values are given in milligrams per litre (mg/l) which is equivalent to parts per million (ppm)
2. ** No flouride was added to Regina water. Flouride measured is naturally occuring.
3. "<" means "less than"
4. "DL" means detection limit

For more information, please contact the City of Regina at 777-7000 or visit: www.regina.ca

REGINA | City of Regina
Infinite Horizons

2014 Drinking Water Quality and Compliance Report

Annual Notice to Customers

Introduction

Saskatchewan Water Security Agency requires that at least once each year, waterworks owners provide notification to consumers of the quality of water produced and supplied as well as information on the performance of the water works in submitting samples as required be the Minister's Order or Permit to Operate a waterworks

The following is a summary of the City of Regina water quality and sample submission compliance records for the period January 1, 2014 - December 31, 2014. This report was completed on March 18, 2014.

Readers should refer to Saskatchewan Ministry of Environment's Municipal Drinking Water Quality Monitoring Guidelines, November 2002, EPB 202 for more information on minimum sample submission requirements and the meaning of each type of sample. Permit requirements for a specific waterworks may require more sampling than outlined in the department's monitoring guidelines. If consumers need more information on the nature and significance of specific water tests, for example, "what is the significance of selenium".
http://www.hc-sc.gc.ca/ewh-semt/pubs/water-eau/index_e.html

Water Quality Standards

I. Bacteriological Quality

Parameter	Limit	Regular Samples Required	Total Samples Tested	No. of Samples Positive of Bacteria
Total Coliform and Background Bacteria	Zero Organisms/100ml Less than 200/100ml	808	807	3

II. Water Disinfection - Chlorine Residual in Distribution System for Test Results Submitted with Bacteriological Samples

Parameter	Minimum Limit (mg/l)	Test Level Range (mg/l)	No. of Tests Required	No. of Tests Performed
Chlorine Residual	0.1 mg/L Free 0.5 mg/l Total	0.08 - 0.94 0.20 - 1.18	808	807

III. Turbidity

Parameter	Limit (NTU)	Test Level Range	No. of Tests Not Meeting Requirements	No. of Tests Required	No. of Tests Performed
Turbidity	**1.0**	**0.09 - 0.60**	**0**	**808**	**807**

(NTU) Nephelometric Turbidity Unit - a unit of measurement used to indicate the clarity of drinking water

IV. Chemical - Trihalomethanes

Parameter	Limit (mg/l)	Sample Result (Average)	No. of Samples Required	No. of Samples Submitted
Trihalomethanes	**0.1**	**0.088 mg/l**	**8**	**31**

Contact Information

More information on water quality and sample submission performance may be obtained from:

City of Regina
306-777-7000
Regina.ca